

## **City Water, Light & Power Coal Combustion Residuals Surface Impoundments**

### **Notification of Statistically Significant Increases in Accordance with 40 CFR 257.95(g)**

City Water, Light and Power (CWLP) owns and operates two (2) existing coal combustion residual (CCR) surface impoundments. The CWLP CCR surface impoundments are located north and east of the former Lakeside Power Generating Station and Dallman Power Generating Station in the Eastern ½ of Section 12, Township 15 North, Range 5 West, in Springfield, Illinois. These CCR surface impoundments are identified as the Lakeside Ash Pond and the Dallman Ash Pond.

Due to statistically significant increases over background concentrations for specific Appendix III parameters at certain wells, assessment monitoring was initiated pursuant to 40 CFR 257.95(b). The initial assessment monitoring sampling event occurred May 4, 2018, with resampling occurring July 9, 2018. Groundwater Protection Standards were subsequently established pursuant to 40 CFR 257.95(d)(2). In accordance with 40 CFR 257.95(g), provided herein is notification of a statistically significant increase above the Groundwater Protection Standard for one parameter, total arsenic at well RW-3.

An investigation has been initiated to evaluate the geochemical properties in the vicinity of RW-3 and is currently ongoing.