

**City Water, Light and Power
Coal Combustion Residuals Surface Impoundments**

**Completion of Corrective Measures in Accordance with
40 CFR 257.96(a)**

July 2019



City Water, Light and Power (CWLP) owns and operates two existing coal combustion residual (CCR) surface impoundments. These CCR surface impoundments are identified as the Lakeside Ash Pond and the Dallman Ash Pond and are located northeast of the power plant complex in Springfield, Illinois. CWLP has begun to characterize the nature and extent of the release in accordance with 40 CFR 257.95(g)(1), however due to poor weather conditions much of the site has been inaccessible and in May 2019 CWLP utilized the 60 day extension in accordance with 40 CFR 257.96(a). Finally, due to 40 CFR 257.95(g)(5) the surface impoundments must either retrofit and/or close, which are the long term corrective measures. CWLP has not made a decision on either retrofitting and/or closing the impoundments at this point in time due to the complexities of our system (all CCR and non-CCR material going to these impoundments are wet-generated, not dry). CWLP has initiated the alternative closure requirements in accordance with 40 CFR 257.103(a)(1) and will be submitting an annual progress report in May of 2020 updating the status of the impoundments.

Certified in accordance with 257.96(a) by: William E. Antonacci
William Antonacci, P.E.

Date: 6/26/19

